

INDOOR AIR HYGIENE GROUP

Ref.-No.: KKL/1045/21

Essen, 14 July 2021

Order-No.: 81 19 38 53 09

GrV/Stem

TÜV NORD Systems
GmbH & Co. KG
ISGBW Testing

Am TÜV 1
45307 Essen, Germany
+49 201 825 - 3204
GBTesting@tuev-nord.de
www.tuev-nord.de

TÜV®

Report No.: TR-KKL-2021-070-R1

Test on an Air Cleaner System

Client

VFA Solutions B.V.

Admiraal de Ruyterstraat 2
3115 HB Schiedam, The Netherlands

Testing object

Air Cleaner System
"ASPRA elektrostatic precipitation section"
with filter "EF-80 + HAF-2 = EF-110"

Order

D404/600313-20210315 7
dated 17.03.2021

Arrival of the testing object

13.04.2021

Content of order

Determination of retention efficiency for different particle sizes and air flow rates and – if definable – documentation of the "Most Penetration Particle Size" using monodisperse particulate matter of DEHS

Standard of test

Based on DIN EN ISO 29463-5:2019

Test period

April to June 2021

This revised report replaces the previous test report TR-KKL-2021-070 dated 08 July 2021.

The test report consists of 7 pages.

The test results refer exclusively to the test objects.

It is not permitted to publish extracts from the report without the written permission of TÜV NORD Systems GmbH & Co. KG.

Headquarters
TÜV NORD Systems GmbH & Co. KG

Große Bahnstrasse 31
22525 Hamburg
Phone: +49 40 8557-0
Fax: +49 40 8557-2295
info@tuev-nord.de
www.tuev-nord.de

Chairman of the Supervisory Board
Dr. Dirk Stenkamp

Registration Office
Amtsgericht Hamburg
HRA 102137
VAT No.: DE 243031938
Tax No.: 27/628/00031

General Partner
TÜV NORD Systems
Verwaltungsgesellschaft mbH, Hamburg

Registration Office
Amtsgericht Hamburg
HRB 88330
Director
Dr. Ralf Jung (CEO)
Silvio Konrad
Ulf Theike

1 Introduction

The Air Cleaner System "ASPRA elektrostatic precipitation section" of VFA Solutions is tested based on "DIN EN ISO 29463-5:2019" and the standards cited therein.

Chapter 2 provides a general overview of the test object and test conditions. The results of the test are listed in Chapter 3. The tests are carried out in the Air Hygiene Testing Laboratory, DMT GmbH & Co. KG, Essen (Germany).

2 Testing object and test conditions

2.1 Description of the test object

Figures 1 and 2 show a photograph and the identification plate of the tested Air Cleaner System.




Figure 1: Photograph of the Air Cleaner System –
"ASPRA elektrostatic precipitation section"
(integrated in the test rig)




Figure 2: Identification plate of the Air Cleaner System – "ASPRA elektrostatic precipitation section"

2.2 Test conditions and procedure

The test object is set up in a test rig according to DIN EN ISO 29463-5:2019. In contrast to the standard, the test object is an air cleaner system and not only a filter element. Adapters are used to connect the test object to the test rig (cf. Figure 1).

The determination of the retention efficiency follows chapter 8.4.1 and 8.4.2 according to DIN EN ISO 29463-5:2019. The test aerosol is DEHS (di-ethyl-hexyl-sebacate). The tests are carried out on two operating points. Point 1: air flow rate 300 m³/h and particle size range 0,07 – 0,25 µm. Point 2: air flow rate 175 m³/h and particle size range 0,03 – 0,30 µm.

DIN EN ISO 29463-5:2019 ("High-efficiency filters and filter media for removing particles in air – Part 5: Test method for filter elements") describes the test methods for high-efficiency filters. DIN EN 1822-1:2019 ("High efficiency air filters (EPA, HEPA and ULPA) – Part 1: Classification, performance testing, marking") describes the requirements of high efficiency air filters for EPA, HEPA and ULPA classes.

3 Test results

3.1 Retention efficiency at operating point 1

Boundary conditions:

- air flow rate 300 m³/h
- particle size range 0,07 – 0,25 µm
- ionizer: in operation

Table 1: Retention efficiency E₉₅ %

Particle size	Efficiency E ₉₅ %
µm	%
0,070	99,9359
0,087	99,9291
0,107	99,9169
0,132	99,8990
0,164	99,8744
0,202	99,8482
0,250	99,8310

3.2 Retention efficiency at operating point 2

Boundary conditions:

- air flow rate 175 m³/h
- particle size range 0,03 – 0,30 µm
- ionizer: in operation


Table 2: Retention efficiency E₉₅ %

Particle size	Efficiency E ₉₅ %
µm	%
0,030	99,9412
0,044	99,9733
0,065	99,9832
0,095	99,9868
0,139	99,9878
0,204	99,9858
0,300	99,9828

3.3 Complete results of measurements at operating point 1

Table 3 contains all results of the measurements at operating point 1.


Table 3: Measurements at operating point 1

Client/Customer Name of the air cleaner system DMT code		VFA Solutions B.V. ASPRA elektrostatic precipitation section PPS 2 00 056 21.1					
Particle measuring device Test aerosol; aerosol-generator		Up CPC TSI Mod. 3750; Dn CPC Mod. TSI 3750 DEHS monodispers; DMA TSI Mod. 3080					
		Test date					
Nominal flow rate Nominal Air speed in filter medium		300 0,9	m³/h m/s	16.06.2021			
Flow area Average volumetric test flow		0,0921 301,17	m² m³/h	Comment			
Flow Velocity Collector		0,91	m/s	Ionizer in operation Filter: EF-80 + HAF-2 = EF-110			
Pressure drop		p1 [Pa] 51	p2 [Pa] 0	p3 [Pa] 0	p4 [Pa] 0	p5 [Pa] 0	
Average pressure drop Most penetration particle size		51 Pa MPPS is not definable	temperature humidity	24,4 °C 41,0 %			
Penetration _{95%} for MPPS		--	abs. pressure	1002 mbar			
dp [µm]	0,070	0,087	0,107	0,132	0,164	0,202	0,250
P 1 _{95%}	0,0641	0,0709	0,0831	0,1010	0,1256	0,1518	0,1690
P 2 _{95%}							
P 3 _{95%}							
P 4 _{95%}							
P 5 _{95%}							
P _{95%}	0,0641	0,0709	0,0831	0,1010	0,1256	0,1518	0,1690
E _{95%}	99,9359	99,9291	99,9169	99,8990	99,8744	99,8482	99,8310
P	0,0620	0,0686	0,0803	0,0974	0,1197	0,1421	0,1531
Penetration ratio 							
○ average ratio [P 95%] • Penetration ratio [P]							

3.4 Complete results of measurements at operating point 2

Table 4 contains all results of the measurements at operating point 2.

Table 4: Measurements at operating point 2

Client/Customer Name of the air cleaner system DMT code		VFA Solutions B.V. ASPRA elektrostatic precipitation section PPS 2 00 056 21.1				
Particle measuring device Test aerosol; aerosol-generator		Up CPC TSI Mod. 3750; Dn CPC Mod. TSI 3750 DEHS monodispers; DMA TSI Mod. 3080				
		Test date				
Nominal flow rate Nominal Air speed in filter medium		175 0,5	m³/h m/s	24.06.2021		
Flow area Average volumetric test flow		0,0921 175,03	m² m³/h	Comment		
Flow Velocity Collector		0,53	m/s	Ionizer in operation Filter: EF-80 + HAF-2 = EF-110		
Pressure drop		p1 [Pa] 23	p2 [Pa] 0	p3 [Pa] 0	p4 [Pa] 0	p5 [Pa] 0
Average pressure drop Most penetration particle size		23	Pa	temperature MPPS is not definable	23,2	°C
Penetration _{95%} for MPPS		--		humidity abs. pressure	50,2	%
dp [µm]	0,030	0,044	0,065	0,095	0,139	0,204
P 1 _{95%}	0,0588	0,0267	0,0168	0,0132	0,0122	0,0142
P 2 _{95%}						0,0172
P 3 _{95%}						
P 4 _{95%}						
P 5 _{95%}						
P _{95%}	0,0588	0,0267	0,0168	0,0132	0,0122	0,0142
E _{95%}	99,9412	99,9733	99,9832	99,9868	99,9878	99,9858
P	0,0568	0,0259	0,0163	0,0126	0,0113	0,0123
Penetration ratio						
						
○ average ratio [P 95%] • Penetration ratio [P]						

4 Conclusion

The Air Cleaner System "ASPRA elektrostatic precipitation section" of VFA Solutions is tested with the method described above. It is not possible to determine the Most Penetrating Particle Size ("MPPS") and a filter class according to DIN EN 1822-1 cannot be assigned. The results show a retention efficiency between 99,8310 % and 99,9359 % at operating point 1 and between 99,9412 % and 99,9878 % at operating point 2 for the Air Cleaner System "ASPRA elektrostatic precipitation section".

Essen, 14 July 2021

Dipl.-Ing. Vera Gräff

Project manager Indoor Air Hygiene Group